



Town of Victor  
 Planning & Building Department  
 85 East Main Street  
 Victor, NY 14564  
 Ph. 585 742-5035 Fax (585) 742- 0202  
 E-mail: codes@townofvictorny.gov

## Fumigation Operating Permit Application

Fumigation Operating Permits are required by Chapter 26 of the Fire Code of the State of New York.

Applicant / Business Information			
Business Name			Chemicals being used
Mailing Address			
Applicant / Contact	Title	E-mail	Cell Phone
Corporate Name		Corporate Address	
Corporate Contact	Title	E-mail	Phone
Activity Information			
Address of fumigation	Date of Fumigation	Time of fumigation	Time building will be safe to re-enter

The following information is required when applicable. Please supply the following documents.

- Certificate of Workman’s Compensation Insurance
- Certificate of Liability Insurance
- Certificate of Disability Insurance
- A Code compliant fumigation plan
- \$25.00 fee payable to the Town of Victor (Permit will not be processed until fee is paid.)

Applicant Signature	
<p><b><i>Acceptance does not relieve the Applicant, Business, Parent Corporation or Agents thereof, from complying with all applicable provisions of the law and or codes whether stated, implied, or omitted in the application and submitted documentation. Incorrect information or failure to maintain the provisions of the permit, applicable codes, and laws, may result in revocation or suspension of the permit.</i></b></p> <p><b><i>I further state I have a copy of Chapter 26 of the Fire Code of New York State and certify our facility has initiated a code compliant fumigation plan.</i></b></p>	
Signature	Date

Office Use Only			
\$25 Fee Paid	Occupancy Class	Authorized Date	Receipt #
Documentation Accepted	Construction Type	Issue Date	
	Fire Chief Notified	Expiration Date	

Chapter 26 of the Fire Code, Fumigation and Insecticidal Fogging may be found on the reverse side of this form.

The entire fumigation process applied for on revers side of the page, shall comply with each code section below.

#### §FC2603 FIRE SAFETY REQUIREMENTS

**FC2603.1 General.** Buildings, structures and spaces in which fumigation and insecticidal fogging operations are conducted shall comply with the fire protection and safety requirements of Sections FC2603.2 through FC2603.7.

**FC2603.2 Sources of ignition.** Fires, open flames and similar sources of ignition shall be eliminated from the space under fumigation or insecticidal fogging. Heating, where needed, shall be of an *approved* type.

**FC2603.2.1 Electricity.** Electricity in any part of the building, structure or space where operation of switches or electrical devices, equipment or systems could serve as a source of ignition shall be shut off.

**Exception:** Circulating fans that have been specifically designed for utilization in hazardous atmospheres and installed in accordance with NFPA 70.

**FC2603.2.2 Electronic devices.** Electronic devices, including portable equipment and cellular phones, shall be shut off. Telephone lines shall be disconnected from telephones.

**FC2603.2.3 Duration.** Sources of ignition shall be shut off during the fumigation activity and remain shut off until the ventilation required in Section FC2603.6 is completed.

**FC2603.3 Notification.** The *fire code official* and fire chief shall be notified in writing not less than 48 hours before the building, structure or space is to be closed in connection with the utilization of any toxic or flammable *fumigant*. Notification shall give the location of the enclosed space to be fumigated or fogged, the occupancy, the *fumigants* or insecticides to be utilized, the person or persons responsible for the operation, and the date and time at which the operation will begin. Written notice of any *fumigation* or *insecticidal fogging* operation shall be given to all affected occupants of the building, structure or space in which such operations are to be conducted with sufficient advance notice to allow the occupants to evacuate the building, structure or space. Such notice shall inform the occupants as to the purposes, anticipated duration and hazards associated with the fumigation or insecticidal fogging operation.

**FC2603.3.1 Warning signs.** *Approved* warning signs indicating the danger, type of chemical involved and necessary precautions shall be posted on all doors and entrances to the affected building, structure or space and on all gangplanks and ladders from the deck, pier or land to a ship. Such notices shall be printed in red ink on a white background. Letters in the headlines shall be not less than 2 inches (51 mm) in height and shall state the date and time of the operation, the name and address of the person, the name of the operator in charge, and a warning stating that the affected building, structure or space shall be vacated not less than 1 hour before the operation begins and shall not be reentered until the danger signs have been removed by the proper authorities.

**FC2603.3.2 Breathing apparatus.** Persons engaged in the business of fumigation or insecticidal fogging shall maintain and have available *approved* protective breathing apparatus.

**FC2603.3.3 Watch personnel.** During the period fumigation is in progress, except where fumigation is conducted in a gas-tight vault or tank, a responsible watchperson shall remain on duty at the entrance or entrances to the enclosed fumigated space until after the fumigation is completed and the building, structure or space is properly ventilated and safe for occupancy. Sufficient watchers shall be provided to prevent persons from entering the enclosed space under *fumigation* without being observed.

**FC2603.3.4 Evacuation during fumigation.** Occupants of the building, structure or space to be fumigated, except the personnel conducting the fumigation, shall be evacuated from such building, structure or space prior to commencing fumigation operations.

**FC2603.3.5 Evacuation during insecticidal fogging operations.** Occupants in the building, structure or space to be fogged, except the personnel conducting the insecticidal fogging operations, shall be evacuated from such building, structure or space prior to commencing fogging operations.

**FC2603.4 Insecticidal fogging liquids.** Insecticidal fogging liquids with a *flash point* below 100°F (38°C) shall not be utilized.

**FC2603.5 Sealing of buildings, structures and spaces.** Paper and other similar materials that do not meet the flame propagation performance criteria of Test Method 1 or Test Method 2, as appropriate, of NFPA 701 shall not be used to wrap or cover a building, structure or space in excess of that required for the sealing of cracks, casements and similar openings.

**FC2603.5.1 Maintenance of openings.** All openings to the building, structure or space to be fumigated or fogged shall be kept securely closed during such operation.

**FC2603.6 Venting and cleanup.** At the end of the exposure period, fumigators shall safely and properly ventilate the premises and contents; properly dispose of fumigant containers, residues, debris and other materials used for such fumigation; and clear obstructions from gas-fired appliance vents.

**FC2603.7 Flammable fumigants restricted.** The use of carbon disulfide and hydrogen cyanide shall be restricted to agricultural fumigation.